

**BIDS AND AWARDS COMMITTEE**

**SUPPLEMENTAL BID BULLETIN NO. 01**

**Replacement of Air Conditioning System at Ground Floor to 3<sup>rd</sup> floor of PNOC Bldg.5**

**Invitation to Bid No. 2024-06-071**

The PNOC Bids and Awards Committee hereby adopts the following provision in the Philippine Bidding Documents:

1. Amendments/Inclusions

Item No.	FROM	TO
1	<p>Section III. Bid data Sheet ITB Clause 5.3 Pages 17</p> <p>For this purpose, contracts similar to the Project shall be:</p> <p>Supply and Installation of Centralized Air Conditioning Project within the last five (5) years prior to the deadline for submission and opening of bids.</p> <p style="text-align: center;">xxx</p>	<p>Section III. Bid data Sheet ITB Clause 5.3 Pages 17</p> <p>For this purpose, contracts similar to the Project shall be:</p> <p>Supply and Installation of Centralized <b>or Variable Refrigerant Flow (VRF)</b> Air Conditioning Project within the last <i>five (5)</i> years prior to the deadline for submission and opening of bids.</p> <p style="text-align: center;">xxx</p>

**MAIN OFFICE**

PNOC Building 6, Energy Center  
Rizal Drive, Bonifacio Global City  
Taguig, Philippines 1634  
(+632) 8789 7662  
www.pnoc.com.ph

**INDUSTRIAL PARK**

Barangay Batangas Dos, Mariveles  
Bataan, Philippines 2105  
(+6347) 244 5884 and 86  
industrialpark@pnoc.com.ph

**ENERGY SUPPLY BASE**

Barangay Mainaga, Mabini  
Batangas, Philippines 4202  
+63 917 515 4036  
energysupplybase@pnoc.com.ph

2	Section VII. Technical Specifications Material Requirement, Item 12 Page 33	Section VII. Technical Specifications Material Requirement, Item 12 Page 33
	xxx	xxx
	12. Pump shall be flexibly coupled to a NEMA frame open drip-proof electric motor, 1750rpm suitable for 230V, 3 phase, 60Hz power supply.	12. Pump shall be flexibly coupled to a NEMA frame open drip-proof electric motor, 1750rpm suitable for <b>220V</b> , 3 phase, 60Hz power supply.
	xxx	xxx

2. Clarifications

Item No.	Clarification	Resolution
1	For Item 15 page 33, all materials supplied should be designed to adopt with 220V, is it possible to have the 50 TR capacity unit in 440V?	Yes. It is possible to have the 50 TR capacity air conditioning unit in 440V but bidder must provide the necessary transformer/equipment.

Amendments/inclusions/clarifications made herein shall be considered an integral part of the Bidding Documents.

For guidance and information of all concerned.

Issued this July 09, 2024.

*Originally Signed*

**ATTY. JOSEPHINE CASSANDRA J. CUI**  
Chairperson  
Bids and Awards Committee